



Water Utility Information (FY 2014)							
B a s i c s	Name of utility:	Chiba Prefectural Waterworks Bureau		Service type:	Water service provider		
	Administrative population:	3.5 million people		Start of service:	1936		
	Population served:	3 million people		Service area:	566.37	km ²	
	Water supply volume						
	Average daily water supply:	870,000	m3/d	Break down	Household use	690,000	m ³ /d
					Commercial and institutional use:	120,000	m ³ /d
					Others:	50,000	m ³ /d
					From wholesale supplier	13,000	m ³ /d
	Average daily water supply per capita:	292	L/per son/d	Service coverage:	96.4	%	
	Effectiveness:	98.7	%	Revenue water:	94.7	%	
	NRW:	5.3	%	Water loss	1.6	%	
	Water rates						
	Water rates for 10m3/month:			1,020 yen (including taxes) *Calculation conditon: The service pipe has a 13-mm diameter. The fixed charge is 410.10 yen/month. The volumetric charge is 61.56 yen/m3 up to 10m3.			
	Water production cost:	181.85	yen/m ³	Water supply cost:	202.39	yen/m ³	

F a c i l i t i e s	Water Treatment Plant and Facilities (including water from wholesale supplier):	Name		Capacity		Water source	Treatment process		
		Kuriyama WTP		186,000	m ³ /d	Surface water (river)	Coagulation/Sedimentation + Rapid filtration + Chlorine disinfection		
		Kashiwai WTP (west wing)		360,000	m ³ /d	Surface water (river)	Coagulation/Sedimentation + Rapid filtration + Chlorine disinfection		
		Kashiwai WTP (east wing)		170,000	m ³ /d	Surface water (lake)	Coagulation/Sedimentation + Rapid filtration + Ozone + Powdered activated carbon + Chlorine disinfection		
		Hokuso WTP		126,700	m ³ /d	Surface water (river)	Coagulation/Sedimentation + Rapid filtration + Chlorine disinfection		
		Fukumasu WTP		90,000	m ³ /d	Surface water (lake)	Coagulation/Sedimentation + Pre-ozonation + Rapid filtration + Ozone + Biological activated carbon + Chlorine disinfection		
		Chiba Nogiku-no-Sato WTP		60,000	m ³ /d	Surface water (river)	Coagulation/Sedimentation + Ozone + Biological activated carbon + Rapid filtration + Chlorine disinfection		
		Water for wholesale supply		261,300	m ³ /d	—	—		
		Total		1,254,000 m ³ /d					
P i p e s	Pipeliene length:	8,970	km	Conveyance:	70	km	Trans mission:	170	km
				Distribution:	8,730	km	Others:	—	km
	Type of material:	•Cast iron: 8,530 km •Asbest cemento: 6.9 km •Steel: 167 km							
O t h e r s	Other information:	•Number of employees: 875 •Seismic reinforcement rate of pumping stations: 79.8% •Seismic reinforcement rate of distribuion reservoirs: 56.5% •Maximum daily supply: 1 million m3 •Maxiumum facility utilization rate: 82.8% (Maximum daily supply/treatment capacity) •Facility utilization rate: 69.2% (Average daily water supply/treatment capacity)							
	Remarsk:	•All the infromaiton above (except for the length of the lead service pipe) was cited from the Annual Report FY2014 of the Chiba Prefectural Waterworks Bureau. •The length of the lead service pipe was cited from the Annual Report FY2013.							



Water Utility Information (FY 2014)



● Case study facility



Case Study Report (Chiba Nogiku-no-Sato Water Treatment Plant)	
W a t e r T r e a t m e n t P r o c e s s	Case #1: Chiba Nogiku-no-Sato Water Treatment Plant
	Key word: Advanced water treatment (ozone + biological activated carbon), Surface water (river), Odor control, Elimination and consolidation of facilities, Private sector involvement
	Outline: <p><Outline and characteristics></p> <ul style="list-style-type: none"> ● Purpose of construction The Chiba Nogiku-no-Sato Water Treatment Plant began operation in October 2007. It's a seismic resistant plant built to replace the old Kogasaki (1940) and Kuriyama (1958) Water Treatment Plants. Upon its completion, the Kogasaki was demolished in 2007. The Kuriyama will also be out of service in 2023, when the Chiba Nogiku-no-Sato will have completed an ongoing construction of a new water treatment facility that will fully replace the capacity of the Kuriyama. ● System features <ul style="list-style-type: none"> • Safe and high quality water supply: Ozone + biological activated carbon (advanced water treatment) to control musty odor as well as bad smells from fish eggs • Emergency preparedness: Seismic resistance reinforcement of water facilities and preparation of on-site water supply stations for residents in the event of an emergency • Private sector involvement: Private Finance Initiative (PFI) for the construction and operation of its drainage facility. The operation contract is for 20 years. Among others, the contract provides for the use of surplus soil from on-site excavations as raw materials of improved soil for reclaimed land. • Environmental measures: Solar power generation system for clean energy • Recreational area for the public: areas on the top of reservoirs is open to public access for recreational use. • Barrier-free design: assures all the visitors a comfortable access to the buildings and facilities on the premises <p><Others> The service area includes portions of the Matsudo City, Ichikawa City, and Funabashi City in the Chiba Prefecture.</p>
	Address: Kuriyama 478-1, Matsudo City, Chiba Prefecture
	Land area: 125,000 m ²
	Water treatment process: Coagulation/Sedimentation + Ozone + Biological Activated Carbon + Rapid filtration + Chlorine disinfection
	Capacity: <ul style="list-style-type: none"> • Final capacity: 246,000 m³/d (to be complete in 2023) • Current capacity: 60,000 m³/d • Additional capacity under construction: 186,000 m³/d
	Water source: Surface water (Edo River of the Tone River System)


Case Study Report (Chiba Nogiku-no-Sato Water Treatment Plant)		
	Raw water quality:	<ul style="list-style-type: none"> ■ Affected by upstream river conditions because of the plant's downstream location ■ Frequent oil spills ■ Algae blooms tend to increase the pH and adversely affect the coagulation process ■ An issue of musty odor and fish eggs flowing from upstream <p><Average raw water quality in FY2014 (maximum)></p> <ul style="list-style-type: none"> • Turbidity: 11 degrees (24 degrees) • Hardness: 60mg/L (68mg/L) • TOC: 1.5 mg/L (2.9 mg/L) • pH: 7.7 (8.7) • Color: 10 degrees (64 degrees) • Geosmin: 0.002 µg/L (0.004 µg/L) • 2-MIB: <0.001 µg/L (0.005 µg/L) • TON: 21 (40)
	Chemical dose:	Sulfuric acid (pH adjustment), Sodium hydroxide (pH adjustment), Polyaluminum chloride (coagulation), Sodium hypochlorite (disinfection)
	Start of operation	Oct-07
Water Treatment Process	Layout:	<p>Aerial view</p> 
	Treatment process flow diagram:	 <pre> graph LR Intake[Intake] --> ReceivingWell[Receiving well] ReceivingWell --> RapidMixing[Rapid mixing] RapidMixing --> Flocculation[Flocculation] Flocculation --> ChemicalSedimentation[Chemical sedimentation] ChemicalSedimentation --> Ozone[Ozone] Ozone --> ActivatedCarbon[Activated Carbon] ActivatedCarbon --> SecondaryChlorinationMixing[Secondary Chlorination mixing] SecondaryChlorinationMixing --> SecondaryMixing[Secondary mixing] SecondaryMixing --> RapidFiltration[Rapid filtration] RapidFiltration --> TertiaryChlorinationMixing[Tertiary Chlorination mixing] TertiaryChlorinationMixing --> Reservoir[Reservoir] Reservoir --> Pumping[Pumping] SulfuricAcid[Sulfuric acid] --> Intake PreChlorination[Pre-chlorination • (Pre-alkali agent)] --> ReceivingWell PrePACl[Pre-PACl] --> RapidMixing PowderedActivatedCarbon[Powdered activated carbon (depending on raw water quality)] --> Intake SecondaryPACl[Secondary PACl] --> SecondaryMixing TertiaryChlorination[• Tertiary chlorination • (Secondary alkali agent)] --> TertiaryChlorinationMixing ChlorineAdjustment[Chlorine adjustment] --> Reservoir subgraph AdvancedWaterTreatment [Advanced Water Treatment] Ozone ActivatedCarbon end </pre>

Case Study Report (Chiba Nogiku-no-Sato Water Treatment Plant)

Instake point



Grit chamber



Sedimentation basin




Ozone diffusing pipe





Activated carbon adsorption basin

Pictures:



Rapid filtration basin



Case Study Report (Chiba Nogiku-no-Sato Water Treatment Plant)		
W a t e r T r e a t m e n t P r o c e s s	Other facilities:	<p>● Solar Power Generation System for CO2 reduction Maximum output: 57.8 kw (daily output varies depending on the weather) Installation area: 410 m2 (324 solar power generation modules) Usage: supplies power for ventilation fans in the central control building</p> <div><p>Solar panel</p></div>
		Order/contract: PFI (drainage facility)
	Other information:	
<div>List of references (URL)<ul style="list-style-type: none">● Chiba Prefectural Waterworks Bureau. Annual Report FY2014. http://www.pref.chiba.lg.jp/suidou/souki/toukeidata/h26zigyou-nenpou.html● Chiba Prefectural Waterworks Bureau. Brochure of the Chiba Nogiku-no-Sato Water Treatment Plant (September 2012).● Chiba Prefectural Waterworks Bureau. Chapter 8: Water Quality Management, the Environment Report FY2014. https://www.pref.chiba.lg.jp/suidou/souki/zigyougaiyou/kankyoukaikai/houkokusho-h26.html● Association of Water and Sewage Works Consultants Japan. Suikon 2015 Vol. 50. http://www.suikon.or.jp/suikon/vol.50/suikon50_009.pdf</div>		


Water Utility Information (FY 2014)						
Basics	Name of utility:	Public Enterprises Agency Kanagawa Prefectural Government		Service type:	Water service provider	
	Administrative population:	3.03 million people		Start of service:	1933	
	Population served:	2.8 million people		Service area:	808.59 km ²	
	Water supply volume					
	Average daily water supply:	880,000 m ³ /d	Break down	Household use	664,000 m ³ /d	
				Commercial and Industrial use:	152,000 m ³ /d	
				Others:	42,000 m ³ /d	
				From wholesale supplier	25,000 m ³ /d	
	Average daily water supply per capita:	292.6 L/person/d	Service coverage:		99.8 %	
	Effectiveness:	92.7 %	Revenue water:		88.5 %	
	NRW:	11.5 %	Water loss		6.7 %	
Water rates						
Water rate for 10m3/month:			1,043 yen (including taxes)			
			**Calculation condition: The fixed charge is 1,420 yen/two months. The volumetric charge is 128 yen/m3 from 17 to 30 m3 = 1,932 yen x taxes x 1/2			
Water production cost:	164.14 yen/m ³	Water supply cost:		156.01 yen/m ³		
Facilities	Water Treatment Plant and Facilities (including water from wholesale supplier):	Name	Capacity	Water source	Treatment process	
		Samukawa WTP	750,000 m ³ /d	Surface water	Coagulation/sedimentation + Rapid filtration + Chlorine disinfection	
		Tanigahara WTP	242,800 m ³ /d	Subsoil water Surface water	Sedimentation + Slow filtration + Chlorine disinfection Coagulation/sedimentation + Rapid filtration + Chlorine disinfection	
		Kamasawa WTP	720 m ³ /d	Surface water	Membrane filtration + Chlorine disinfection	
		Ochiai WTP	1,620 m ³ /d	Surface water	Membrane filtration + Chlorine disinfection	
		Wada WTP	360 m ³ /d	Surface water	Membrane filtration + Chlorine disinfection	
		Oyama WTP	1,100 m ³ /d	Surface water	Membrane filtration + Chlorine disinfection	
		Sokozawa WTP	470 m ³ /d	Surface water	Membrane filtration + Chlorine disinfection	
		Toya WTP	5,550 m ³ /d	Subsoil water	Coagulation/sedimentation + Rapid filtration + Chlorine disinfection	

		Nagano WTP	500 m ³ /d	Subsoil water	Membrane filtration + Chlorine disinfection
		Itarih WTP	4,400 m ³ /d	Spring water	Membrane filtration + Chlorine disinfection
		Shinanoki WTP	3,300 m ³ /d	Spring water	Membrane filtration + Chlorine disinfection
		Midono water source	12,800 m ³ /d	Spring water	UV treatment + Chlorine disinfection
		Others (Kissawa etc)	1,700 m ³ /d	Ground water	Chlorine disinfection
		Water from wholesale supplier	669,400 m ³ /d	—	—
		Total	1,694,720 m ³ /d		
Pipes	Pipeline length:	9,217 km	Conveyance:	12 km	Transmission: 221 km
			Distribution:	8,984 km	Others: — km
	Type of material:	<ul style="list-style-type: none"> •Cast iron: 6,381km •Steel: 481km •Stainless: 14km 			
Others	Other information:	<ul style="list-style-type: none"> •Number of employees: 623 •Seismic reinforcement rate of pumping stations: 4.8% •Seismic reinforcement rate of distribution reservoirs: 21.6% •Maximum daily supply: 1.04 million m³/day •Maximum facility utilization rate: 68.5% (Maximum daily supply/treatment capacity) •Facility utilization rate: 62.9% (Average daily water supply/treatment capacity) 			
	Remarks:	<ul style="list-style-type: none"> •The information in the Basics, Facilities and Pipes sections (except for the pipeline length, pipe material and ratio of lead service pipe) was cited from the Annual Statistics Report FY2014 of the Kanagawa Prefectural Government. http://www.pref.kanagawa.jp/uploaded/attachment/801189.pdf •The pipeline length and pipe material is based on the registry of the fixed assets of the Kanagawa Prefectural Government. •The information on the lead service pipe and the seismic reinforcement ratio (except for the one of primary mains) was cited from the PI guidelines for water supply services FY2014. http://www.pref.kanagawa.jp/uploaded/life/1005094_3294728_misc.pdf •The seismic reinforcement ratio of primary mains is based on the reference material below. http://www.pref.kanagawa.jp/uploaded/attachment/832973.pdf 			


Water Utility Information (FY 2014)

S
e
r
v
i
c
e

a
r
e
a



Overview of facilities



Case Study Report (Samukawa Water Treatment Plant)	
W a t e r t r e a t m e n t p r o c e s s	Case #2-1 Samukawa Water Treatment Plant
	Key word: Surface water (river), Rapid filtration
	<p>Outline:</p> <p><Characteristics></p> <ul style="list-style-type: none"> ● Features of the Samukawa Water Treatment Plant • Reliable water supply: The Samukawa Water Treatment Plant has a distribution management system to monitor and control reservoirs and pumping stations in the utility's distribution network. On the premises there are two water treatment plants called No. 2 and No 3 WTPs (No. 1 WTP has been demolished). These two plants are responsible for an efficient and reliable distribution management based on demand forecasts as well as for mutual water transfers with other utilities. • Environmental measures: Solar power generation system. Surplus soil from on-site excavations is recycled as raw materials of cement additives. • Private sector involvement: A Private Finance Initiative (PFI) has been used for the construction and operation of the drainage facility. <p><Outline></p> <ul style="list-style-type: none"> • The Samukawa Water Treatment Plant is situated in the Samukawa Town approximately 6.5 km upstream from the estuary of the Sagami River. The Samukawa intake weir located in the town abstracts water from the river. The water treatment process consists of a coagulation/sedimentation, filtration and disinfection. • Service area: 11 Cities and 4 Towns • Capacity: 750,000 m³/d (No. 2 WTP: 210,000 m³/d + No. 3 WTP: 540,000 m³/d)
	Address: Miyagawa 4271, Samukawa Town, Kanagawa Prefecture
	Land area: 487,229m ²
	Water treatment process: Coagulation/sedimentation + Rapid filtration + Chlorine disinfection
	Capacity: 750,000 m ³ /d
	Water source: Surface water (Sagami River)
	<p>Raw water quality:</p> <p>■ Since the raw water is taken from downstream of the Sagami River, it tends to be adversely affected by phytoplankton growth and artificial contaminations in upstream river bodies and lakes.</p> <p><Average raw water quality in FY2014 (maximum)></p> <ul style="list-style-type: none"> • Turbidity: 9.1 degrees (51 degrees) • Hardness: 59 mg/L (68mg/L) • TOC: 0.8 mg/L (1.3 mg/L) • pH: 7.8 (7.9) • Color: 3.4 degrees (12 degrees) • Geosmin: 0.002μg/L (0.004μg/L) • 2-MIB: <0.002 μg/L (0.007 μg/L) • TON: 8 (17)
	Chemical dose: Sulfuric acid (pH adjustment), Sodium hydroxide (alkalinity adjustment), Polyaluminum chloride (coagulation), Sodium hypochlorite (disinfection)
	Start of operation: Dec-63

Case Study Report (Samukawa Water Treatment Plant)

Layout:

An aerial photograph of the Samukawa Water Treatment Plant. The image shows a large industrial facility with numerous rectangular treatment basins, some of which are filled with water. There are several buildings, including a large green-roofed structure, and a railway line runs along the bottom of the image. The surrounding area is a mix of greenery and urban development.

Water
treatment
process

The diagram illustrates the water treatment process at the 2nd and 3rd Water Treatment Plants, showing the flow from the Sagami River through various treatment stages.

2nd Water Treatment Plant:

- Sagami River** (Source)
- Sand settling basin**
- Junction well** (Receives **Sulfuric acid**)
- Intake pump** (Receives **sodium hydroxide** and **sodium hypochlorite**)
- Receiving well** (Receives **sodium hydroxide** and **sodium hypochlorite**)
- Rapid mixing** (Receives **Polyaluminum chloride**)
- Flocculation**
- Sedimentation (horizontal)** (Receives **sodium hypochlorite**)
- Filtration receiving well**
- Filtration**
- Clear water storage** (Receives **sodium hydroxide** and **sodium hypochlorite**)

3rd Water Treatment Plant:

- Sagami River** (Source)
- Sand settling basin** (Receives **Powdered activated carbon**)
- Intake pump** (Receives **Pre-PACI**)
- Receiving well and rapid mixing** (Receives **Polyaluminum chloride** and **sodium hydroxide**)
- Flocculation**
- Sedimentation (inclined plate)** (Receives **Pre-chlorination**)
- Filtration** (Receives **Secondary Chlorination** and **Pre-chlorination**)
- Clear water storage** (Receives **sodium hydroxide** and **sodium hypochlorite**)

Connections:

- The **Clear water storage** of the 2nd plant feeds into the **Intake pump** of the 3rd plant.
- The **Clear water storage** of the 3rd plant feeds into the **Clear water storage** of the 2nd plant.

Case Study Report (Samukawa Water Treatment Plant)

Water treatment process

Pictures:

● Intake point



● Sand settling basin



● Flocculation basin



● Sedimentation basin



● Rapid filtration basin



Other facilities:

- Solar Power Generation System for CO2 reduction
Maximum output: 120 kw (daily output varies depending on the weather)
Installation: Feb 2005
Location: on the top cover of filtration basins



- Backup Power Supply System
The backup power supply system enables the No. 2 and No. 3 water treatment plants to continue operation when a blackout cuts the commercial power supply from the Tokyo Electric Power Company.

Other information

- The Brochure of the Samukawa Water Treatment Plant (June 2015)
- The Water Quality Report of the Kanawaga Prefectural Government's Water Supply Service (Jan 2016)

Case Study Report (Tanigahara Water Treatment Plant)	
W a t e r t r e a t m e n t p r o c e s s	Case #2-2 Tanigahara Water Treatment Plant
	Key word: Surface water (lake), Slow filtration
	<p>Outline:</p> <p><Characteristics></p> <ul style="list-style-type: none"> •Efficient and Reliable water supply: The Tanigahara Water Treatment Plant has a monitoring and control system for not only on-site facilities but outside reservoirs and pumping stations of the utility's distribution network, providing an efficient and reliable water supply. To improve the treated water quality, automated feeders of activated carbon were installed in 2010. •Multiple water treatment processes: the plant has two trains of water treatment processes with the one using slow filtration and the other rapid filtration. The latter has three types of sedimentation methods: horizontal, inclined plate, and rapid ones. •Environmental measures: Surplus soil from on-site excavations is recycled as raw materials of cement additives <p><Outline></p> <ul style="list-style-type: none"> •Built in 1942 to address a rapid increase in water demand in the Sagami-hara Region. •Service area: 2 Cities and 1 Town •Capacity: 242,800 m³/d (slow filtration system: 32,800 m³/d + rapid filtration system: 210,000 m³/d)
	Address: Tanigahara 2-6-1, Midori-ku, Sagami-hara City, Kanagawa Prefecture
	Land area: 91,492m ²
	<p>Water treatment process:</p> <p>1. Slow filtration system: Sedimentation + Slow filtration + Chlorine disinfection 2. Rapid filtration system: Coagulation/sedimentation + Rapid filtration + Chlorine disinfection</p>
	Capacity 242,800 m ³ /d
	Water source: Surface water, Subsoil water (Sagami River)
	<p>Raw water quality:</p> <p>■ Mostly abstracted from the Sagami Lake, the raw water tends to contain a range of phytoplanktons including synedra (clogging filtration basin), microcystis (affecting filtrate turbidity) and anabaena (musty odor).</p> <p><Average raw water quality in FY2014 (maximum)></p> <ul style="list-style-type: none"> •Turbidity: 7.6 degrees (35 degrees) •Hardness: 53 mg/L (61 mg/L) •TOC: 0.8 mg/L (1.3 mg/L) •pH: 7.8 (8.5) •Color: 6 degrees (22 degrees) •Geosmin: 0.003μg/L (0.008μg/L) •2-MIB: <0.001 μg/L (0.002 μg/L) •TON: 3 (5)
	Chemical dose: Sulfuric acid (pH adjustment), Calcium hydroxide (alkalinity adjustment), Polyaluminum chloride (coagulation), Sodium hypochlorite (disinfection)
	<p>Start of operation</p> <p>Mar-40</p>

Case Study Report (Tanigahara Water Treatment Plant)



Water treatment process

Layout

● Arial view



Water treatment process flow



Case Study Report (Tanigahara Water Treatment Plant)

W
a
t
e
r

t
r
e
a
t
m
e
n
t

p
r
o
c
e
s
s

Pictures

● Intake point



● Sedimentation basin (slow filtration system)



● Coagulation/sedimentation basin (rapid filtraion system - horizontal)



● Coagulation/sedimentation basin (rapid filtraion system)



● Slow filtration basin



● Rapid filtration basin



Other facilities:

● Backup Power Supply System

In the event of a blackout cuts the commercial power supply, a backup power generator enables the operation for up to one fourth of the total plant capacity.



Other information

- The Brochure of the Tanigahara Water Treatment Plant (March 201)
- The Water Quality of the Kanawaga Prefectural Government's Water Supply Service (Jan 2016)

Case Study Report (Oyama Water Treatment Plant)		
W a t e r t r e a t m e n t p l a n t	Case #2-3	Oyama Water Treatment Plant
	Key word:	Membrane filtration, surface water (river)
	Outline:	<Characteristics> •Demand fluctuation management: Situated in a tourist zone, the Oyama Water Treatment Plant has relatively broad water demand fluctuations throughout the year but has been producing drinking water in a safe and reliable manner. <Outline> •With a capacity of 740 m ³ /d, it abstracts water from the Oyama River and supplies about 270 households in the Oyama and Koyasu Districts. •Service area: portions of 1 City
	Address:	Sakamoto 671, Oyama, Isehara City, Kanagawa Prefecture
	Land area:	592m ²
	Treatment process:	Sedimentation + Membrane filtration + Chlorine disinfection
	Capacity	1,000 m ³ /d
	Water source:	Surface water (Oyama River)
	Raw water quality:	■Abstracted from a mountaineous region, the raw water has a high quality with little artificial contaminations. <Average raw water quality in FY2014 (maximum)> •Turbidity: 0.6 degrees (2.3 degrees) •Hardness: 36 mg/L (38 mg/L) •TOC: 0.5 mg/L (1.7 mg/L) •pH: 7.6 (7.7) •Color: 2.1 degrees (6.4 degrees) •Geosmin: <0.001μg/L (-) •2-MIB: <0.001 μg/L (-) •TON: 3 (5)
	Chemical dose:	Sodium hypochlorite (disinfection)
	Start of operation:	April 1986 (membrane filtration since 1998)

Case Study Report (Oyama Water Treatment Plant)


Layout

● Outside appearance



Water treatment process

Treatment process flow diagram:



Case Study Report (Oyama Water Treatment Plant)

Water treatment plant

Pictures


● Intake point



● Intake point



● Settling basin, Sedimentation basin (when covered)



● Settling basin, Sedimentation basin (when opened)



● Membrane filtration system



● Membrane filtration system



Other facilities:

● Membrane module
12 m³ x 34 modules x 3 trains (102 modules in total)
Filtration method: external pressure type dead-end filtration
Filtration velocity: 1.0 m³/m²*d (maximum)
Module size: φ114×1,078 mm

Other information

- The Brochure of the Oyama Water Treatment Plant (June 2010)
- The Water Quality Report of the Kanawaga Prefectural Government's Water Supply Service (Jan 2016)

Case Study Report (Midono Water Source)	
W a t e r t r e a t m e n t p r o c e s s	Case #2-4 Midono Water Source
	Key word: UV treatment system, Spring water
	Outline: <ul style="list-style-type: none"> <Chracteristics> •Environmental measures: Because of a very high raw water quality throughout the year, a UV treatment system has been adopted, saving energy required for water treatment. •Service area: portions of 1 Town •Design capacity: 12,800 m3/d
	Address: Sengokuhara Daigatake 1277-2, Hakone Town, Kanagawa Prefecture (location of the UV treatment system)
	Land area: 16,127m ²
	Water treatment process: UV treatment + Chlorine disinfection
	Capacity: 12,800 m3/d
	Water source: Spring water
	Raw water quality: <ul style="list-style-type: none"> ■Although influenced by volcanic soil, the raw water has a very high quality with little contaminations. <Average raw water quality in FY2014 (maximum)> •Turbidity: <0.1 degrees (<0.1 degrees) •Hardness: 110 mg/L (110 mg/L) •TOC: <0.1 mg/L (0.1 mg/L) •pH: 7.2 (7.2) •Geosmin: <0.001µg/L (-) •2-MIB: <0.001 µg/L (-) •TON: <1 (<1)
	Chemical dose: Sodium hypochlorite (disinfection)
	Start of operation: Mar-68

Case Study Report (Midono Water Source)


Water treatment process

Layout

● Midono Water Source



Treatment process flow diagram:



Case Study Report (Midono Water Source)			
Water treatment process	Pictures:	<div>● Intake facility</div> 	<div>● Intake facility</div> 
		<div>● Spring water (inside the intake facility)</div> 	<div>● UV system (outside)</div> 
		<div>● UV system</div> 	<div>● UV system structure</div> 
		<div>● UV treatment system</div> <div>Irradiation dose: over 10mJ/cm2</div> <div>Size of irradiation tank: φ500 mm x 2400 mm</div> <div>Number of UV lamps: 6 lamps/unit</div> <div>Size of a UV lamp: φ19 mm x 1500 mm</div>	
	Other facilities:		
Other information			
<div>• The Brochure of the Kanagawa Prefectural Government's Water Service in the Hakone Town (Apr 2014)</div> <div>• The Water Quality Report of the Kanagawa Prefectural Government's Water Supply Service (Jan 2016)</div>			


Case Study Report (Kissawa Water Source)		
W a t e r t r e a t m e n t p r o c e s s	Case #2-5	Kissawa Water Source
	Key word:	Ground water, Chlorine disinfection only
	Outline:	<Characteristics> •Safe and refreshing drinking water: the ground water has a very good quality throughout the year. <Outline> •Service area: the ground water is used to suppliment reservoirs of other water treatment plants. •Maximum capacity: 1,100 m3/d 1st well: φ75×60m 2nd well: φ125 x 12 m、φ100 x 48 m
	Address:	Tsuchiya 1760, Hiratsuka City, Kanagawa Prefecture
	Land area:	322m ²
	Water treatment process:	Chlorine disinfection
	Capacity:	1,100 m3/d
	Water source:	Ground water
	Raw water quality:	■ The raw water has a very high quality with little contaминаions. <Average raw water quality in FY2014 (maximum)> •Turbidity: <0.1 degrees (<0.1 degrees) •Hardness: 140 mg/L (140 mg/L) •TOC: 0.2 mg/L (0.3 mg/L) •pH: 7.6 (7.9) •Geosmin: <0.001μg/L (-) •2-MIB: <0.001 μg/L (-)
	Chemical dose:	Sodium hypochlorite (disinfection)
	Start of operation:	Unknown

Case Study Report (Kissawa Water Source)


Water treatment process

● Overview





Layout:



Treatment process flow diagram:



```
graph LR; W1[Well] --> W2[Well]; W2 --> P((P)); P --> M((M)); M --> R{R}; R --> R1[Reservoir]; R1 --> R2[Reservoir]; R2 --> CT1[Customer tap]; R2 --> RT[Receiving tank]; RT --> CT2[Customer tap];
```

Case Study Report (Kissawa Water Source)		
W a t e r t r e a t m e n t p r o c e s s	Pictures	<div>● Well (outside)</div>  <div>● Well (inside)</div> 
		<div>● Intake facility</div>  <div>● Pumping facility</div> 
	Other facilities:	—
Other information:		
<ul style="list-style-type: none"> • The Water Quality Report of the Kanawaga Prefectural Government's Water Supply Service (Jan 2016) 		



Water Utility Information (FY 2014)							
B a s i c s	Name of utility:	Osaka Water Supply Authority		Service type:		Wholesale water supply	
	Administrative population*1:	6.2 million people		Start of service*2:		2011	
	Population served*1:	6.1 million people		Service area*3:		1100.46	km ²
	Volume of water supply						
	Average daily water supply:	1.4 million	m ³ /d	Break down	Household use	—	m ³ /d
					Commercial and institutional use:	—	m ³ /d
					Others:	—	m ³ /d
					Wholesale water supply	1.4 million	m ³ /d
	Average daily water supply per person*4:	252.3	L/person/d	Service coverage:		—	%
	Effectiveness:	100.0	%	Revenue water:		100.0	%
	NRW:	0.0	%	Water loss		0.0	%
	Note: as a wholesale supplier, service coverage is not applicable. NRW and water loss are both 0%.						
	Water rates						
	Water rates for 10m3/month:			— yen (including taxes)			
	Water production cost:	64.35	yen/m ³	Water supply cost:		75	yen/m ³

Water Utility Information (FY 2014)									
F a c i l i t i e s	Water Treatment Plants:	Name		Capacity		Water source		Treatment process	
		Murano WTP		1,797,000	m ³ /d	Surface water		Coagulation/sedimentation + Rapid filtration + Ozone + Granular activated carbon + Chlorine disinfection	
		Niwakubo WTP		203,000	m ³ /d	Surface water		Coagulation/sedimentation (only in the event of high turbidity events) + Biological treatment (contact filtration) + 2nd coagulation + Rapid filtration + Ozone + Granular activated carbon + Chlorine disinfection	
		Mishima WTP		330,000	m ³ /d	Surface water		Biological treatment (honeycomb tube) + Coagulation/sedimentation + Rapid filtration + Ozone + Granular activated carbon + Chlorine disinfection	
		Total		2,330,000	m ³ /d				
P i p e s	Pipeline length:	573.19	km	Conveyance:	16.698	km	Transmission :	549.363	km
				Distribution :	0	km	Others:	7.129	km
	Type of material:	•Cast iron 35.560 km •Ductile iron 435.630 km •Steel 101.999 km •Stainless 0.025 km							
O t h e r s	Other information:	•Number of employees: 376 •Seismic reinforcement rate of pumping stations: 100% •Seismic reinforcement rate of distribtuion reservoirs: 10.4% •Maximum daily supply: 1.56 million m3 •Maxiumum facility utilization rate: 66.9% (Maximum daily supply/treatment capacity) •Facility utilization rate: 60.7% (Average daily water supply/treatment capacity)							
	Remarks:	● Primary reference materials • Osaka Prefectural Government. Water Supply Service in the Osaka Prefecture in FY2014. http://www.pref.osaka.lg.jp/kankyoeisei/suido/genkyo-26.html • Osaka Water Supply Authority. Water Suply Statistics Annual Report FY2014. http://www.wsa- osaka.jp/siryoushu/toukei-nepo/26toukei_index.html *1 The administrative population and the population served are those of the 42 municipalities in the Osaka Prefecture (excluding the Osaka City) in FY2014. *2 The water supply department of the Osake Prefectural Government (the predecessor of the Osaka Wate Supply Authority) was created in 1940 and began water supply in 1951. *3 Of the 42 municipalities in the Osaka Prefecture (excluding the Osaka City) in FY2013. *4 Of the 42 municipalities in the Osaka Prefecture (excluding the Osaka City) in FY2012. *5 The water treatment plants for industrial users are not listed here.							

Water Utility Information (FY 2014)

S
e
r
v
i
c
e

a
r
e
a



Service area

● Case study facility

Case Study Report (Murano Water Treatment Plant)	
W a t e r T r e a t m e n t P r o c e s s	Case #3
	Murano Water Treatment Plant
	Key word: Advanced water treatment (ozone + granular activated carbon), Multi-story water treatment facility, Water pressure differential power generation, Surface water (river)
	Outline: <p><Outline></p> <ul style="list-style-type: none"> •The Murano Water Treatment Plant is responsible for approximately 80% of the utility's water production. •Ozonation and granular activated carbon (GAC) treatment was installed in 1998 to address issues of musty odor and trihalomethane. <p><Characteristics></p> <ul style="list-style-type: none"> •One of the largest water treatment plants in Japan in terms of capacity •One of the first water treatment plants in Japan that adopted ozone and GAC •A very rare, multi-story water treatment facility <p><Multi-story water treatment facility></p> <ul style="list-style-type: none"> •The multi-story water treatment facility contains the equipments for sedimentation, filtration, ozonation, GAC treatment etc. These equipments are located on the multiple stories of two connected buildings. Each building has a capacity of 275,000 m³/d. The operation started in July 1980. (The advanced water treatment process was installed in 1994 in the multi-story water treatment facility.) •When a water demand increase in the 1970s required an enhancement of the utility's water supply capacity, there was not enough available area on the premises to build a new facility. The utility thought it better, however, if a new facility could use some of the existing Murano facilities so they wouldn't have to build new ones. Their answer was the multi-story water treatment facility that requires much smaller site space and thus allows for more efficient daily inspections and repair work of the equipments. •The facility has a pressure differential power generation system. Using a 10-meter difference in water levels among basins, it provides a maximum electricity of 240 kw. The accumulated electricity in 2014 was 1.41 million kWh.
	Address: Murano Takamidai 7-2, Hirakata City, Osaka Prefecture
	Land area: 317,756 m ²
	Water treatment process: Coagulation/sedimentation + Rapid filtration + Ozone + GAC + Chlorine disinfection
	Capacity: 1,797,000 m ³ /d
	Water source: Surface water (Yodo River)
	Raw water quality: <ul style="list-style-type: none"> ■ Since the plant abstracts water from the downstream of the Yodo River, the raw water is affected by the use in the upstream side of the river. It used to contain much ammonia nitrogen but its concentration has decreased to a non-significant level in recent years due to a development of sewage infrastructure. ■ Because of an influence from the Lake Biwa situated upstream of the Yodo River, the raw water tends to be adversely affected by musty odor, picoplankton growth, and algae growth during summer that increase the pH. <p><Average raw water quality in FY2014 (maximum)></p> <ul style="list-style-type: none"> •Turbidity: 8 degrees (62 degrees) •Hardness: 42.6 mg/L (45.1 mg/L) •TOC: 1.8 mg/L (2.4 mg/L) •pH: 7.4 (7.8) •Color: 20 degrees (190 degrees) •Geosmin: 0.001 µg/L (0.004 µg/L) •2-MIB: 0.004 µg/L (0.014 µg/L) •TON: 24 (30)
	Chemical dose: Sulfuric acid (pH adjustment), Sodium hydroxide (pH adjustment), Polyaluminum chloride (coagulation), Sodium hypochlorite (disinfection)
	Start of service: 1963/7/1

Case Study Report (Murano Water Treatment Plant)


Water Treatment Process

Layout

● Aerial view



Treatment process flow diagram:






● The multi-story water treatment facility has 72.3 m in length, 88.8 m in depth and 31.1 m in height.



Sectioned diagram of the multi-story water treatment facility

Pictures




Case Study Report (Murano Water Treatment Plant)	
W a t e r T r e a t m e n t P r o c e s s	<p> ● A solar power generation system: installed on the top cover of sedimentation basins. The cover also helps prevent algae growth. The maximum output is 360 kW. ● A pressure differential power generation system: the multi-story water treatment facility generates power by utilizing the difference in water pressure between the chlorine mixing basin and the treated water reservoir. </p> <div> <div>Other facilities:</div>   <p>Pressure differential power generation system</p> </div> <p> ● Organic compound sensors in the intake station continuously monitor volatile organic compounds in the raw water. ● Carp Sensor is also installed in the intake station for continuous monitoring of the raw water quality. </p>
	Order/contract: —
	Expenses: Unknown
	Other information
	Reference: Osaka Water Supply Authority. Commemorative Publication for the Establishment of the Osaka Water Supply Authority. http://www.wsa-osaka.jp/event-pr/pamphlet/

Water Utility Information (FY 2014)							
B a s i c s	Name of utility:	Water and Sewer Bureau of the City of Kitakyushu		Service type:		Wholesale and retail water supply	
	Administrative population:	957,000		Start of service:		1907	
	Population served:	995,000		Service area:		270.16	km ²
	Water supply volume						
	Average daily water supply:	310,000	m ³ /d	Break down	Household use	213	m ³ /d
					Commercial and institutional use:	61	m ³ /d
					Others:	1.3	m ³ /d
					Wholesale water supply	12	m ³ /d
	Average daily water supply per capita:	311	L/person/d	Service coverage:		99.6	%
	Effectiveness:	93.11	%	Revenue water:		90.4	%
	NRW:	2.69	%	Water loss		6.66	%
	Water rates						
	Water rates for 10m ³ /month:			842 / 780 yen (including taxes/excluding *Calculation condition: The fixed charge is 680 yen. The volumetric charge is 10 yen/m ³ . In case of service pipe of 13-mm diameter.			
	Water production cost:	145.21	yen/m ³	Water supply cost:		144.65	yen/m ³
F a c i l i t i e s	Water Treatment Plant and Facilities (including water for wholesale supply):	Name		Capacity		Water source	Treatment process
		Ideura WTP		255,200	m ³ /d	Dam, subsoil water, surface water	Coagulation/sedimentation + Rapid filtration
		Dobaru WTP		7,800	m ³ /d	Dam	Slow filtration
		Hata WTP		24,000	m ³ /d	Dam	Coagulation/sedimentation + Rapid filtration
		Ano WTP		300,000	m ³ /d	Dam, surface water	Biological contact filtration + Coagulation/sedimentation + Rapid filtration
		Honjo WTP		141,000	m ³ /d	Dam, surface water	Biological contact filtration + Coagulation/sedimentation + Rapid filtration
		Total		728,000	m ³ /d		
P i p e s	Pipeliene length:	4,518.2	km	Conveyance:	188.6	km	Transmission : 230.8 km
				Distribution :	4,098.6	km	Others: — km
	Type of material:	• Ductile iron 3950.6 km • Cast iron 265.7 km • Steel 98.8 km • Others (GP, VLP, etc) 156.4 km					
O t h e r s	Other information:	• Number of employees: 379 • Maximum daily supply: 340,000 m ³ • Maxiumum facility utilization rate: 44.4% (Maximum daily supply/treatment capacity) • Facility utilization rate: 40.2% (Average daily water supply/treatment capacity)					
	Remarks:	● Kitakyushu City Water and Sewer Bureau. Outline of the Water and Sewer Services: https://www.city.kitakyushu.lg.jp/suidou/soo101009.html					

Water Utility Information (FY 2014)

S
e
r
v
i
c
e

a
r
e
a



Service area

● Case study facility

Case Study Report

Case #4

Ano Water Treatment Plant (Upward Biological Contact Filtration: U-BCF)

Key word:

Advanced water treatment, Upward Biological Contact Filtration, Taste and Odor, Surface water (dam)

<Characteristics>

1. Features of U-BCF

The Upward Biological Contact Filtration (U-BCF) system can remove ammonia nitrogen, dissolved manganese, and musty odor causing substances like geosmin efficiently. Using the U-BCF helped reduce the chemical dose at the Ano Water Treatment Plant.

2. U-BCF in other countries

The *Haiphong Water Supply One Member Company Limited*, the water utility in Haiphong City in Vietnam, has installed a U-BCF system in their Vinh Bao Water Treatment Plant.

<Outline>

•As the utility's primary water treatment plant, the Ano Water Treatment Plant has the capacity of 300,000 m³/d (39% of the total production).

•The U-BCF was developed by the utility itself. It was first installed in 2003.

<Characteristics of U-BCF>

•The core function of the U-BCF is to artificially reproduce a natural environment in which aquatic microorganisms decompose micropollutants in a more efficient manner.

•The filter media is granular activated carbon.


•Due to its porous, rugged, uneven surfaces, the granular activated carbon provides a much better environment than, for example pebbles in a riverbed for microorganisms to live in.

•An upward water flow through the activated carbon layers makes the raw water contact with microorganisms.



•The upward water flow stirs the granular activated carbon, contributing to an improved biological contact.

•When the U-BCF was installed at the Ano Water Treatment Plant, it was placed before the receiving well.

Outline:




U-BCF Facility



Case Study Report


Address:	Takanosu 3-10-16, Yahata-Nishi Ku, Kita-Kyushu City, Fukuoka Prefecture
Land area:	84,150m ²
Water treatment process:	U-BCF + Coagulation/sedimentation + Rapid filtration
Water source:	Surface water (river/dam)
Raw water quality:	<p>■ The raw water contains much musty odor substances, ammonia nitrogen and manganese.</p> <p><Average raw water quality in FY2014 (maximum)></p> <ul style="list-style-type: none"> •Turbidity: 14 degrees (44 degrees) •Color: 16 degrees (48 degrees) •pH: 7.6 (7.8) •Hardness: 66 mg/L (102 mg/L) •TOC: 1.8 mg/L (2.7 mg/L) •Ammonia nitrogen: 0.02 mg/L (0.09 mg/L) •Dissolved manganese: 0.007 mg/L (0.033 mg/L) •Geosmin: 0.002 µg/L (0.006 µg/L) •2-Methylisoborneol (2-MIB): 0.001 µg/L (0.002 µg/L)
Chemical dose:	As for the U-BCF, it requires no chemical dose.
Capacity:	171,000 m ³ /d
Start of operation:	The U-BCF started operation in 2003 in the Ano Water Treatment Plant (in 2000 in the Honjo Water Treatment Plant).



Water supply network, City of Kitakyushu



Case Study Report

Treatment process flow diagram:



Case Study Report		
W a t e r t r e a t m e n t p r o c e s s	Pictures	<div>   </div> <div> <div>Ano Water Treatment Plant</div> <div>Upward Biological Contact Filtration (U-BCF)</div> </div>
	Other facilities:	Small-size hydropower generation system
	Order/contract:	Tendering
	Expenses:	Unknown
	Other information:	
	—	

Water Utility Information (as of 2016)								
B a s i c s	Name of utility:		Bureau of Waterworks Tokyo Metropolitan Government		Service type:		Wholesale + Retail water supply	
	Administrative population:		13.74 million people		Start of service:		1898	
	Population served:		9.37.5 million people		Service area:		626.79	km ²
	Volume of water supply							
		Average daily water supply:	4.11 million	m ³ /d	Break down	Household	2.96 million	m ³ /d
						Industrial	37,000	m ³ /d
						Urban	1.11 million	m ³ /d
		Average daily water supply per person:	-	L/person/d	Service coverage:	100	%	
		Effectiveness:	96.7	%	Revenue water:	96.0	%	
		NRW:	4.0	%	Water loss	3.1	%	
	Water rates							
		Water rates for 10 m ³ /month:				1,047/970 yen (with taxes/without taxes)		
						**Calculation condition: the fixed charge is 860 yen and the volumetric charge is 0 yen for 13 mm at 1-5 m ³ use and 22 yen/m ³ at 6-10 m ³ use.		
		Water production cost:	208.95	yen/m ³	Water supply cost:	211.61	yen/m ³	


Water Utility Information (as of 2016)									
F a c i l i t i e s	Water Treatment Plants: (including the water received for wholesale supply)	Name		Capacity		Water source		Treatment process	
		Kanamachi WTP		1,500,000	m³/d	Tone River ・ Arakawa River		Rapid filtration ・Advanced water treatment (applied entirely)	
		Misato WTP		1,100,000	m³/d	Tone River ・ Arakawa River		Rapid filtration ・Advanced water treatment (applied entirely)	
		Asaka WTP		1,700,000	m³/d	Tone River ・ Arakawa River		Rapid filtration ・Advanced water treatment (applied entirely)	
		Mikuni WTP		300,000	m³/d	Tone River ・ Arakawa River		Rapid filtration ・Advanced water treatment (applied entirely)	
		Higashimurayama WTP		1,265,000	m³/d	Tone River ・ Arakawa River ・ Tamagawa River		Rapid filtration ・Advanced water treatment (applied partially for 880,000 m³/d of Tone River ・ Arakawa River waters)	
		Ozaku WTP		280,000	m³/d	Tamagawa River		Rapid filtration	
		Sakai WTP		315,000	m³/d	Tamagawa River		Slow filtration	
		Kinuta WTP		114,500	m³/d	Tamagawa River		Membrane filtration ・ Slow filtration	
		Kinutashimo WTP		70,000	m³/d	Tamagawa River		Membrane filtration ・ Slow filtration	
		Tamagawa WTP		(152,500)	m³/d	Tamagawa River		Slow filtration ・Rapid filtration	
								*operation suspended due to raw water degradation	
		Nagasawa WTP		200,000	m³/d	Sagamihara water		Rapid filtration	
		Suginami WTP		15,000	m³/d	Ground water		Disinfection only	
		Total		6,859,500	m³/d				
P i p e s	Pipeline length:	27,792	km	Conveyance:	-	km	Transmission:	-	km
				Distribution:	27,038	km	Others:	-	km
	Type of material:	・ Cast iron ・ Steel ・ Others							
O t h e r s	Other information:	・ Number of employees: 3,800 (as of August 1 2017) ・ Maximum daily supply: 4.51 million m³/d ・ Facility utilization rate: 78.6% (maximum daily supply/facility capacity)							
	Remarks:	・ "Overview of the Water Services." Bureau of Waterworks Tokyo Metropolitan Government. https://www.waterworks.metro.tokyo.jp/							

Case Study Report (Asaka Water Treatment Plant)	
Case #5	Asaka Water Treatment Plant
Key word:	Advanced water treatment; raw water accommodation pipeline; solar power generation
Outline:	<p><Characteristics></p> <ol style="list-style-type: none"> 1. Installation of advanced water treatment process Following the Kanamachi Water Treatment Plant (WTP) and the Misato WTP, the Bureau installed an advanced water treatment using ozonation and biological activated carbon process at the Asaka WTP in November 2004. Together with the second-phase facilities completed in March 2014, the advanced treatment now accounts for Asaka's entire water treatment of 1.7 million m³/d. This also means that all the water abstracted from the Tone River and its tributaries are now being treated through the advanced treatment at various WTPs of the Bureau including the Asaka. 2. Mutual accommodation of raw water The Asaka WTP has been connected with the Higashimurayama WTP by a raw water accommodation pipeline. This allows the Asaka to use the Tama River's water when needed, in addition to the water from the Tone River and the Arakawa River. 3. Use of PFI (public finance initiative) Since April 2005, the Asaka has operated its power generation facility and sodium hypochlorite production facility under PFI scheme. <p><Advanced Water Treatment Process></p> <ul style="list-style-type: none"> • The advanced water treatment process consists of an ozonation and a biological activated carbon adsorption. It aims to reliably and efficiently remove substances that cannot be adequately removed by the conventional water treatment processes such as rapid filtration. • The ozonation oxidizes and decomposes substances that can produce musty odor and trihalomethanes. • The biological activated carbon (BAC) adsorption removes pollutants through activated carbon adsorption and decomposition by microorganisms that grow on the carbon. • The Bureau has installed an "ozonation + BAC" before filtration so it comes in as the final treatment process, as it can trap and remove microorganisms that may leak from the BAC layer. This decision was made based on the research and experiments conducted for six years from 1983. • In addition, the Asaka WTP also uses filtration before "ozone + BAC" in order to reduce trihalomethane precursors efficiently and to reduce the power consumption required for ozone injection. <p><Raw water accommodation pipe></p> <ul style="list-style-type: none"> • The utility has installed a "raw water accommodation pipe" that allows raw water from different river systems to be mutually accommodated for efficient use of raw water. • Asaka normally abstracts from the Tone River system, but sending some of its water to the Higashimurayama water treatment plant helps keep enough water stored all the time from the Tama River system, including at the Ogouchi reservoir. • In the event of drought or water quality incidents in the Tone River system, raw water from the Tama River system is used by receiving its water from the Higashimurayama water treatment plant.
Land area:	228,206 m ² (excluding water drainage facility)
Water treatment process:	coagulation + sedimentation + ozonation + granular activated carbon + chlorine disinfection
Water source:	Surface water (rivers)

	<ul style="list-style-type: none"> Because the intake point is located in the lower reaches of the Arakawa River, the concentration is relatively high of water quality parameters that could affect the treatment process, such as organic matters and ammonia nitrogen. In recent years, the concentration of substances that can cause musty odor has been relatively high due to the effects of algae attached to stones on the riverbed. When the amount of water is short for distribution due to drought and other reasons, water is temporarily taken from the Arakawa Reservoir located right in front of the intake point. This water is susceptible to the water quality within the Arakawa Reservoir (especially the substances that can cause musty odor).
Raw water quality:	<p><Average raw water quality in FY2018 (maximum)></p> <p>Turbidity: 12 degrees (740 degrees)</p> <p>Color: 7 degrees (26 degrees)</p> <p>TOC: 1.7 mg/L (2.5 mg/L)</p> <p>Potassium permanganate consumption: 6.0 mg/L (34 mg/L)</p> <p>Ammonia nitrogen: 0.10 mg/L (0.43 mg/L)</p> <p>Iron: 0.43 mg/L (1.0 mg/L)</p> <p>Manganese: 0.076 mg/L (0.099 mg/L)</p> <p>Geosmin: 2 µg/L (20 µg/L)</p> <p>2-MIB: 6µg/L (170 µg/L)</p>
Chemical dose:	sulfuric acid (pH adjustment), caustic soda (pH adjustment), polyaluminum chloride (flocculation), sodium hypochlorite (disinfection), powdered activated carbon (odor removal)
Capacity:	1,700,000 m ³ /d
Start of service	October 1966

Case Study Report (Asaka Water Treatment Plant)

Treatment
flow
diagram:



<Solar power generation system>


Solar panels installed on the top of the filtration basin.

Capacity: 1,200 kW

Solar panels installed on the roof of the second-phase building and on the top of distribution reservoirs.

Capacity: 500kW

Other
facilities:



Order/
contract:


-

Expenses:

Unknown

Other information

<https://www.waterworks.metro.tokyo.jp/suido/jigyo/gaiyou/shisetsu.html>



1. Grit chamber

Sand and soils mixed in the abstracted water are settled.

2. Water pump

Water is pumped into the receiving well.

3. Receiving well

Water pumped up by the water pump is led to the flocculation basin.

4. Chemical mixing basin

Polyaluminum chloride (flocculant) is added to collect and settle fine sand and soil mixed in the water.

5. Flocculation basin

Fine sand and soil mixed in the water are made into flocs that are easy to settle.

6. Sedimentation basin

While the water is slowly flowing, the flocs in the water settle to the bottom to make the water cleaner.

7. Pre-filtration basin

Smaller flocs that cannot be removed in the sedimentation are filtered out using filter sand.

8. Ozone contact basin

Ozone decomposes substances that cause musty odor and trihalomethane.

9. Biological activated carbon adsorption basin

Activated carbon removes the substances decomposed by ozone. Also, the microorganisms grown on the activated carbon decompose ammonia and other substances.

10. Post-filtration basin

The water is filtered again to make it safe and tasty to drink.

11. Chemical mixing area

Sodium hypochlorite is mixed with the filtered water for disinfection.

12. Water distribution reservoir

Clear water is stored.

13. Transmission and distribution pump

The water stored in the distribution reservoir is sent out for distribution.

14. Control room

The room is used to monitor the dosage of various chemicals and water quality.

